



GVM TEST HOUSE
AND RESEARCH CENTRE

23-24, Yashodeep Heights,
Plot No. 14/15, Sector 29C,
Rabale-Ghansoli Node,
Navi Mumbai - 400 701, INDIA.
Phone: +91 93244 69890
Email: lab@gvmtesthouse.com
www.gvmtesthouse.com



ISO 9001:2015 Certified

TESTING | TRAINING | AUDITING

Test Order Ref: GVM/WPC/03069-13-2/03/2023
Date of Receipt: 01.03.2023

Date: 04.04.2023
Page No. 1 of 1

ULTRATECH CEMENT LIMITED

Building Products Division, Plot No. 61/1 & 2,
94/1 & 2A, 95/4, Wada - 421303

TEST REPORT ON LIQUID APPLIED COATING

Source of Sample	:	Sample supplied by the customer.
Number of samples Tested	:	01 (One only).
Customer's Reference	:	PO No. 8C/B03/4500058304
Condition of sample	:	Satisfactory
Lab Reference Number	:	2023/MAR/03069-13-2
Sample Identification #	:	Acrylic 180
Curing Condition #	:	27 ± 2 °C Temperature And 65 ± 5% RH for 14 days
Period of Test	:	06.03.2023 to 22.03.2023
Test Method	:	ASTM D 4803: 2018

TEST RESULTS -

S. N.	Product Name	Surface Temperature (°C)	Reduction in Surface Temp. against Control (°C)
1	Control Sample	52.3	---
2	Acrylic 180	43.4	10.2

As furnished by the customer.

- Note:
1. The results relate only to the items tested.
 2. Report shall not be reproduced except in full, without the written approval of lab.
 3. Any correction invalidates this report.

For GVM TEST HOUSE AND RESEARCH CENTRE



ASHOK NAGAR

Authorised Signatory

Regd. Office:

402, Yogesh Apartment CHS, Plot No. 26, Sector 8A, Airoli, Navi Mumbai - 400 708, INDIA.
GSTIN: 27BPBPB4090Q1ZM